

Mandatory Language for Monitoring and Reporting Violation
Chemical Sampling
CHEMICAL MONITORING, ROUTINE MAJOR

The **Central Texas WSC** water system **PWS ID 0140161** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Public water systems are required to collect and submit chemical samples of water provided to their customers, and report the results of those samples to the TCEQ on a regular basis.

We failed to monitor and/or report the following constituents Chlorite tests were run on incorrect day

This/These violation(s) occurred in the monitoring period(s) **October 2020**

Results of regular monitoring are an indicator of whether or not your drinking water is safe from chemical contamination. We did not complete all monitoring and/or reporting for chemical constituents, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

We are taking the following actions to address this issue:
Chlorine Dioxide machine was on, October 1-5. Lab tests were not performed during that timeframe. Lab tests were run the following week while Chlorine Dioxide machine was off, by mistake. Entering lab results on report were from incorrect folder. Chlorine Dioxide has not been used since October 5, 2020. We notified TCEQ as soon as we became aware. We have included training to ensure labs are performed on schedule and results are saved to current folder on Operations computer.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Central Texas Water Supply Corporation, General Manager, Lee Kelley** at 254-698-2779.

Posted /Delivered on: February 22, 2021
